

CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-E208470
Report Reference E208470-20100504
Issue Date 2016-SEPTEMBER-14

Issued to: GUNTHER SPELSBERG GMBH & CO KG
Im Gewerbepark 1
58579 Schalksmuhle GERMANY

**This is to certify that
representative samples of** AUXILIARY DEVICES
“See Addendum Page”

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508 and CSA C22.2 No. 14-13 - Standard for Industrial
Control Equipment
UL50 and CSA C22.2 No. 94.1-07 - Standard for
Enclosures for Electrical Equipment, Non-Environmental
Considerations
UL50E and CSA C22.2 No. 94.2-07 - Standard for
Enclosures for Electrical Equipment, Environmental
Considerations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-E208470
Report Reference E208470-20100504
Issue Date 2016-SEPTEMBER-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Product Covered:

USL, CNL - Auxiliary Devices, Enclosure Series, Model TG PC followed by 88, 1208, 1212 or 1608 followed by 6 or 9, followed by 'blank' or t, followed by 'blank' or -o and may be followed by S or -SV. Alternate designations for bottom part TG PC followed by 88, 1208, 1212 or 1608 followed by 'blank' or -o

Alternate designation for transparent cover T6-s, T6-sv, T9-s or T9-sv Alternate designation for Intransparent cover 6-s, 6-sv, 9-s or 9-sv

Enclosures without quick-release faster (/S): Type 4X and Type 12

Enclosures with quick-release faster (-SV): Type 12



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

